



November 2, 2009

KITTLESON'S INC.  
JAMES KITTLESON  
2401 27TH STREET  
RICE LAKE WI 54868

Re: Description: SEWAGE TANKS, RV TRANSFER CONTAINER  
Manufacturer: KITTLESON'S INC.  
Product Name: NATURES STOP RV HOLDING TANK  
Model Number(s): 235 (236 TOTAL GALLONS)  
Product File No: 20070337

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of November 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This product may only receive waste from recreational vehicles.
- The joints between the tank cover and the inlets and outlet fittings must be made airtight.
- The glass-fiber, reinforced resin joint between the tank and cover must be of sufficient depth and width to provide a corrosion resistant barrier, and be at least as strong as the tank wall. It must be at least 7/32 inch thick and have a total overlay of at least four inches.
- When this tank is installed to receive wastewater from only recreational vehicles, the tank must be installed by either a licensed plumber or a holder of a servicing license issued pursuant to s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code. All servicing and disposal of the contents from these tanks must be in accord with s. 146.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code.
- This product may only be used as a POWTS holding component in campgrounds permitted by the Department of Health Services under ch. DHS 178 or properties where the use of the camping unit transfer container is permitted by an adopted governmental unit ordinance and monitored by the governmental unit.
- This product was previously listed as a SEWAGE TANK FIBERGLAS.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov  
SBD-10564-E (N.10/97)